

INVITATION TO BID

Addendum # 2



Department Of Executive Services
Finance and Business Operations Division
Procurement and Contract Services Section
206-684-1681 TTY RELAY: 711

ADDENDUM DATE: May 1, 2006

ITB Title: Park Bridges – Pedestrian/Stock

ITB Number: 06-054 PXR

Revised Due Date/Time: May 11, 2006

Buyer: Paul Russell, paul.russell@metrokc.gov, 206-684-1054

Q#	Subsection	Question	Response
1	Cover Addendum #1		DELETE Due Date/Time May 4, 2006-2:00 P.M. Due Date/Time May 5, 2006 REPLACE WITH Due Date/Time May 11, 2006-2:00 P.M.
2	Section 5 Technical Specifications	If these bridges cannot be treated with Penta or CCA, then what type of treatment is recommended? I did not see a section regarding treatment.	CLARIFICATION The following County Hydraulic Project permit language referred to the Western Wood Preservers Institute http://www.wwpinstitute.org/ – Best Management Practices (BPM). BMP - Best Management Practices for the use of Treated Wood in Aquatic Environments and BMP Amendment #1 - ACZA April 18, 2002 ADD to specifications: All lumber to be used for the Park Bridges shall meet or exceed the standards established in “Best Management Practices For the Use of Treated Wood in Aquatic Environments’ developed by the Western Wood Preservers Institute, dated July 1996.

This ITB will be provided in alternative formats such as Braille, large print, audiocassette or computer disk for individuals with disabilities upon request.